

BOARD OF EDUCATION OF JEFFERSON COUNTY, KENTUCKY  
EQUAL OPPORTUNITY/AFFIRMATIVE ACTION EMPLOYER  
C. B. Young, Jr. Service Center  
3001 Crittenden Drive  
Louisville, Kentucky 40209-1104

**DIESEL & GASOLINE**

ADDENDUM NO. 1

**ATTENTION ALL BIDDERS**

Please make the following changes and/or additions to the above named bid and indicate on your bid form the fact that you acknowledge receipt of this addendum.

Bid opening date and time has changed to 11:00 a.m., Eastern Time, Wednesday, October 5, 2016.

**SPECIFICATIONS**

**DIESEL - ASTM D6751**

Items 6, 8 & 10 should read as stated below:

6. The Cetane number shall be a minimum of 45.0 during winter months, November 1<sup>st</sup> through March 31<sup>st</sup> as per ASTM D4737 / ASTM 976 test method.
8. Awarded vendor must submit verification the biodiesel producer is BQ 9000 accredited.
10. All biodiesel fuel shall be blended with #2 ULSD prior to delivery.