

BOARD OF EDUCATION OF JEFFERSON COUNTY, KENTUCKY
EQUAL OPPORTUNITY/AFFIRMATIVE ACTION EMPLOYER
C. B. Young, Jr., Service Center
3001 Crittenden Drive
Louisville, Kentucky 40209-1104

COMPETITIVE NEGOTIATION FOR

WALK-IN COOLER/FREEZER UNITS AND INSTALLATION FOR VARIOUS SCHOOL CAFETERIAS

ADDENDUM NO. 1

ATTENTION ALL BIDDERS

Please note the following changes to the above named bid and indicate on your bid form the fact that you acknowledge receipt of this addendum.

Add the following page after page 21.

Note: All sites to have an 8'6" ceiling height
Wilder ES – Omit roof cap
 Include chase for exposed refrigerant piping
Jeffersontown HS – Internal dimensions are now 190" x 178"

PURCHASING/BID DEPARTMENT

December 12, 2023

PHASE 42 JCPS WALK-IN COOLER/FREEZER UNITS AND INSTALLATION FOR VARIOUS SCHOOL KITCHENS

School Name	WIF Dimensions (WxD)		WIC Dimensions (WxD)		Location		New Condensing Units		Condensor Comments	Floor
	Internal	External	Internal	External	Interior	Exterior	WIF	WIC		
Cochran ES	156" x 129"		132" x 129"		WIF WIC		NEW	NEW	Water Cooled, relocate to floor set on new rack	WIF = Include floor WIC = no floor
Hawthorne ES		150" x 105"		104" x 82"	WIC	WIF	NEW	NEW	Water Cooled, same location as existing, replace existing rack	WIF = Include floor WIC = no floor
Jeffersontown HS	154" x 110"					WIF	NEW		Water Cooled, same location as existing, replace existing rack	WIF = Include floor
Newburg MS	154" x 179"		133" x 179"		WIF WIC		NEW	NEW	Water Cooled, same location as existing, replace existing rack	WIF = Include floor WIC = Include floor
Wilder ES	134" x 85"		110" x 85"			WIF WIC	NEW	NEW	Water Cooled, relocate to floor set on new rack	WIF = Include floor WIC = Include floor